



TOWNSHIP OF MAHWAH FIRE PREVENTION BUREAU

Fire Official Michael Roe
Fire Inspector Ed Garza
Office 201.529.5757
Fax 201.512.0537

Kidde Recalls Smoke/CO Alarm



U.S. **Consumer Product Safety Commission** says smoke and CO Alarm manufacturer Kidde has recalled 3.6 million smoke alarms in the United States.

The recall involves the Kidde Night Hawk talking combo smoke/carbon monoxide alarm with model number KN-COSM-IB and manufacture dates between June 1, 2004 and Dec. 31, 2010.

The alarm can fail to continue to chirp when it reaches its seven year end-of-life, even if the batteries are replaced, leading consumers to believe it is still working. Kidde has received eight reports of incidents with the recalled alarms; no injuries have been reported.

Consumers should Contact: Kidde toll-free at 855-239-0490 from 8 a.m. to 5 p.m. ET Monday through Friday or online at **www.kidde.com** for more information.